



**Request for Bids  
Capehart Restoration Ph. II Excavation Services  
Bid No.: B16-001  
Issue Date: July 17, 2015**

**Addendum No. 1**

The following questions were submitted. The City's responses to the questions follow in *Italics*.

- 1. Q: Will the City be providing any details on the materials to be installed, especially estimated depths of Catch Basins and product data sheets on the associated separator row systems?

*A: F style concrete systems two feet by four feet with two chambers were used on a similar project. The average depth of excavations for the basins were six feet but quote depths up to eight feet. For the compact bio retention systems figure depths are not to exceed eight feet.*

- 2. Q: Is there a cost estimate?

*A: There is no cost estimate.*

All other terms, conditions and specifications remain the same.

Please acknowledge this addendum by signing the acknowledgement below and returning this form with you bid.

If you have already submitted a bid and would like to make a change reflecting this addendum, you may request in writing your bid be returned to you.

The following Addendum(s) is/are hereby acknowledged:

**Addendum No. 1 – Issued July 17, 2015**

\_\_\_\_\_  
Business Name

\_\_\_\_\_  
Name (print or type)