



**Request for Bids
Roof Replacement- Fleet Maintenance**

**Purchasing Department
73 Harlow Street
Bangor, Maine 04401
207-992-4282**

Issue Date: August 1, 2016

Addendum No. 1

The following questions were submitted. The City's responses to the questions follow in *Italics*.

1. Q: How long of a warranty is the City requesting?

A: At a minimum, a 20 year manufacturer's warranty.

2. Q: What if there is insulation that needs to be replaced?

A: Provide a square foot cost of the insulation and an hourly rate to replace it.

Additional Information: Old discontinued heating units are still attached to the roof. Bidders should provide a separate cost to remove them.

All other terms, conditions and specifications remain the same.

Please acknowledge this addendum by signing the acknowledgement below and returning this form with you bid. If you have already submitted a bid and would like to make a change reflecting this addendum, you may request in writing your bid be returned to you.

The following Addendum(s) is/are hereby acknowledged:

Addendum No. 1 – Issued August 1, 2016

Business Name

Name (print or type)

Signature